



CROWN-LINE PLASTICS

P.O. BOX 607, NEBRASKA CITY, NE 68410

Quality Plastic Pipe

Schedule 40 Conduit - Bell End

Meets specifications UL 651 and NEMA TC 2 Rated for 90° C Cable

Sunlight Resistant

UL FILE NUMBER E325410 CONTROL NUMBER 3ST2

Schedule 40 Conduit Belled End 10 foot and 20 foot lengths.

PART #	SIZE	I.D.	O.D.	MIN. WALL	BELL	WT/100'	PALLET
820111	1/2	0.622	0.840	0.109	2.5	16	1800
820112	3/4	0.824	1.050	0.113	2.5	22	4000
820113	1	1.049	1.315	0.133	3	32	4000
820114	1 1/4	1.380	1.660	0.140	3	44	3000
820115	1 1/2	1.610	1.900	0.145	3.5	52	2250
820116	2	2.067	2.375	0.154	3.75	70	1400
820117	2 1/2	2.469	2.875	0.203	3.75	110	930
820118	3	3.068	3.500	0.216	4	150	880
820119	3 1/2	3.548	4.000	0.226	4	175	630
820120	4	4.026	4.515	0.237	6	210	570
820121	5	5.047	5.565	0.258	6	285	380
820122	6	6.065	6.625	0.280	6	365	280

Schedule 40 Conduit Belled End 40' Lengths

PART #	SIZE	I.D.	O.D.	MIN. WALL	BELL	WT/100'	PALLET
820111							
820112							
820113							
820114							
820115							
820116	2	2.067	2.375	0.154	3.75	70	2800
820117	2 1/2	2.469	2.875	0.203	3.75	110	1860
820118	3	3.068	3.500	0.216	4	150	1200
820119	3 1/2	3.548	4.000	0.226	4	175	1260
820120	4	4.026	4.515	0.237	6	210	1160
820121	5	5.047	5.565	0.258	6	285	1520
820122	6	6.065	6.625	0.280	6	365	680